

Electrical Preventive Maintenance Records

Filter: From: 2026-03-31 To: 2026-04-15 Showing 39 record(s) from 2026-03-31 to 2026-04-15 Printed: April 17, 2026

April 2026

DATE	BRANCH CODE	BRANCH NAME	EQUIPMENT	LOCATION	TASK	STATUS	PERFORMED BY	VERIFIED BY	NEXT DUE	NOTES
2026-04-15	SCF	TOMSWORLD	Panel Board	SM FAIRVIEW	INSTALLATION OF BREAKER	OK	Chris Neri / Ronil Jardio	JHAPS DOMINGUEZ		INSTALL BREAKER AND C/O
2026-04-15	SBB	GOTCHA PRIZE	Panel Board	SM BALIWAG	PREVENTIVE MAINTENANCE	OK	Jerico Simon	ARNELO VALENCIA		Balance loads
2026-04-15	SBB	Funhouse	Panel Board	SM BALIWAG	PREVENTIVE MAINTENANCE	OK	Jerico Simon	ARNELO VALENCIA		Balance loads
2026-04-15	SBB	TOMSWORLD	Panel Board	SM BALIWAG	PREVENTIVE MAINTENANCE	OK	Jerico Simon	Arnelo Valencia		PP/LP1 has yellow tag(thermal scan) contactor terminal loosen- status: retightened-ok
2026-04-15	Pwqe	Joy planet inc	Other	Walter mart bicutan	Rectification of smoke detector pwqe	OK	Johny Austria / Joseph Cristal	Micheal Quanico		Rectification of defective smoke detector pwqe
2026-04-15	PWQE	Joy planet inc	Panel Board	Waltermart bicutan	Relocation of machine and Preventive Maintenance and load balancing pwqe	OK	Johny Austria / Joseph Cristal	Micheal Quanico		Relocation of machine /Preventive maintenance and load balancing Pwqe
2026-04-14	MTR	Funhouse	Panel Board	Montalban town center Rizal	Replacement of broken 20 amp breaker 2 sets branches from LP panel Board	OK	Petemar Solano	Edmond Gutierrez Genova		Due to years of using this 20ampher it's may coz of broken And due to additional wattage of lighting from 16 watt to 18 watt canopy light and dome light
2026-04-14	SSJ	TOMSWORLD	Panel Board	SM SAN JOSE DEL MONTE	Preventive Maintenance	OK	Jerico Simon	Joden Robles		LP/PP is unbalance(L1-26A,L2-12A,L3-15A) causing L1 to Heat up(yellow tag).After balancing,(L1-17.2A,L2-17.5A, L3-18.2A). PP gotcha-loose neutral bus bar,retightened.. Subject for thermal scanning again
2026-04-14	PSCS	PAMBI CORP	Panel Board	Sm sucat	Preventive Maintenance relocation of machine and Load balancing pscs	OK	Johny Austria / Joseph Cristal	Chris Baral		Preventive maintenance Relocation of machine and Liad balancing pscs
2026-04-14	Pph3	JOY PLANET INC	Panel Board	Sm Southmall Iaspinas	Relocation of machine and Preventive Maintenance /Load Balancing Pph3	OK	Johny Austria / Joseph Cristal	Mark Quitaleg		Relocation of machine/Preventive maintenance and Load balancing pph3.
2026-04-13	Pplp	Pambi corp	Lighting	Festivall mall Alabang	Replacement busted lights pplp	OK	Johny Austria / Joseph Cristal	Melvin torreste		Replacement busted lights pplp

DATE	BRANCH CODE	BRANCH NAME	EQUIPMENT	LOCATION	TASK	STATUS	PERFORMED BY	VERIFIED BY	NEXT DUE	NOTES
2026-04-13	ECO	TOMSWORLD	Baseboard	ever commonwealth	repair floor outlet	OK	Chris Neri	lemuel mabansag		wiring and topping floor outlet
2026-04-13	SPB	TOMSWORLD	Panel Board	SM PULILAN	Re tightening of terminals in breakers and neutral busbar	OK	Jerico Simon	Oscar Gaviola		Re tightening of screws on the back of breaker and busbar:done. Subject for another thermal scanning by admin..
2026-04-13	RCR	TOMSWORLD	Panel Board	Robinson Cainta Rizal	Preventive maintenance	OK	Petemar Solano	Allain Christian Porpayas		Unbalanced of load subject for relocation of machine PP3 neutral wire to busbar subject for cutting of burn out wire before or After operation
2026-04-11	PEWF	PAMBI CORP	Baseboard	Festival mall alabang	Replacement of defective outlet baseboard in pewf	OK	Johny Austria / Joseph Cristal	Edgie Onsing		Replacement defective outlet baseboard in pewf
2026-04-11	MOP	Funhouse	Panel Board	Morong CenterPoint Morong Rizal	Conduct electrical safety certificate	OK	Jerico Simon / Petemar Solano	Francis Carelo		Status:ok
2026-04-11	MOP	Funhouse	Panel Board	Morong CenterPoint,Morong Rizal	Preventive Maintenance	OK	Jerico Simon / Petemar Solano	Francis Carelo		Unbalance due to aircon units
2026-04-11	TYT	Funhouse	Panel Board	Tanay Town Center	Conduct electrical safety certificate	OK	Jerico Simon / Petemar Solano	Kenneth Rosales		Status:ok
2026-04-11	TYT	Funhouse	Panel Board	Tanay Town Center	Preventive Maintenance	OK	Jerico Simon / Petemar Solano	Kenneth Roasales		Unbalance due to aircon units
2026-04-10	SEO satellite area	TOMSWORLD	Panel Board	Sm East Ortigas	Preventive maintenance	OK	Petemar Solano	Rafael domens		LP / PP main panel Board balance of load
2026-04-10	SEO	JACKS ADVENTURE	Panel Board	Sm East Ortigas	Preventive maintenance	OK	Petemar Solano	Rafael domens		LP / PP main balance of load
2026-04-10	SEO	TOMSWORLD	Panel Board	Sm East Ortigas	Preventive maintenance	OK	Petemar Solano	Rafael domens		All panel board balance of load
2026-04-10	EWM	Funhouse	Panel Board	EAST WOOD	PREVENTIVE MAINTINANCE	OK	Chris Neri / Ronil Jardio	KEVYN PULLON		LOAD BALANCE AND CLEANING PANEL BOARD
2026-04-09	PSTH	JOY PLANET INC	Panel Board	Sm southmall laspinas	Re tappings federline burn at psth gotcha and balancing load And preventive maintenance	OK	Johny Austria / Joseph Cristal	Mark quitaleg		Re tapping and Rectifi federline burn at breaker psth gotcha laspinas
2026-04-08	PTT	Funhouse	Panel Board	pure gold taguig	preventive maintinance	OK	Chris Neri / Ronil Jardio	kevyn pullon		load balance and cleaning panel board
2026-04-08	SPB	TOMSWORLD	Panel Board	SM PULILAN	Preventive Maintenance	OK	Jerico Simon	John Oliver Caballes		Balance loads

DATE	BRANCH CODE	BRANCH NAME	EQUIPMENT	LOCATION	TASK	STATUS	PERFORMED BY	VERIFIED BY	NEXT DUE	NOTES
2026-04-08	Tempo 2 pplp	PAMBI CORP	Lighting	Pixie festival mall alabang	Replacement busted lights tempo 2 pplp dome ligjts.	OK	Johny Austria / Joseph Cristal	Melvin torreste		Replacement busted lights tempo 2 pplp dome lights
2026-04-08	PPLP	PAMBI CORP	CCTV UTP Cable	Pixie forest festival mall alabang	Rectification Of Wiring cctv Camera pplp	OK	Johny Austria / Joseph Cristal	Melvin torreste		Rectification of wiring cctv camera pplp
2026-04-07	smm	TOMSWORLD	Panel Board	sm mega mall	preventive maintainance	OK	Chris Neri / Ronil Jardio	kevyn pullon		loud balance and cleaning panel board
2026-04-07	WCP	Funhouse	Panel Board	Waltermart Plaridel	Preventive Maintenance	OK	Jerico Simon	Eizen Perez		Unbalance loads due to 3 ACCUs
2026-04-07	smm	TOMSWORLD	Panel Board	sm mega mall	preventive maintainance	OK	Chris Neri / Ronil Jardio	Sir Ian		Load balancing
2026-04-07	Ppl1	PAMBI CORP	Transformer	X site festival mall alabang pl1	Preventive Maintenance Power Transformer ppl1 xsite	OK	Johny Austria / Joseph Cristal	Mary cris Del rosario		Preventive maintenance Power Transformer xsite ppl1
2026-04-07	Pplp	PAMBI CORP	Transformer	Pixie festival mall alabang	Preventive Maintenance Power Transformer pplp pixie	OK	Johny Austria / Joseph Cristal	Melvin torreste		Preventive maintenance Power Transformer pplp pixie.
2026-04-06	MTR	Funhouse	Panel Board	Montalban Town Center	Replacement of defective breaker	OK	Jerico Simon / Petemar Solano	Lorenzo Arsenal		Status:ok
2026-04-06	MTR	Funhouse	Lighting	Montalban Town Center	Replacement of defective downlights	OK	Jerico Simon / Petemar Solano	Lorenzo Arsenal		Status:ok
2026-04-06	Pplp	PAMBI CORP	Other	Festival mall alabang	Preparing Electrical materials for new satellite pixie pplp	OK	Johny Austria / Joseph Cristal	Melvin Torreste		Preparing electrical materials for new satellite pplp pixie festival mall alabang.
2026-04-05	MTR	Funhouse	Panel Board	Montalban town center	Replacement of burn out breaker	Completed	Petemar Solano	Edmond Gutierrez Genova		All branches of 20 Amp is over years to used it's may coz immediate to trip and broken
2026-04-05	MTR	Funhouse	Panel Board	Montalban town center	Replacement of burn out branches 20 Amp breaker	OK	Petemar Solano	Sir Edmond Gutierrez Genova		All branches are long years to use GE type it's may cuz' to trip due to over use from years 2008 up to 20206

March 2026

DATE	BRANCH CODE	BRANCH NAME	EQUIPMENT	LOCATION	TASK	STATUS	PERFORMED BY	VERIFIED BY	NEXT DUE	NOTES
2026-03-31	Sm lipa batangas	TOMSWORLD	Other	Sm lipa batangas	Ocular and coordinate mall admin new satellite area sm lipa	Ongoing	Johny Austria / Joseph Cristal	Ah Honelyn tan		Ocular and coordinate admin mall for new satellite Sm lipa batangas.